

Data Center Noise Measurements

On Sunday, December 7, 2025, I took a field trip to survey low frequency sounds emitting from existing data centers in Pflugerville and Round Rock.

Measurements were taken using an iPhone 17 Pro Max and the LFD (for Low Frequency Detection) app, specifically engineered to detect and measure low frequency sounds. These are the sometimes inaudible sounds often emitted by data center operations. While they are often not heard audibly, they can be experienced as vibrations, which can be very harmful with extended exposure. Measurements at each location were taken for a single, 60-second period, which is the standard measurement period for this app. The software was calibrated before each reading was taken.

All measurements were taken from either public property (e.g., sidewalks or roads) or from publicly accessible locations of businesses such as parking lots that are open to the public.

I did not measure traditional, audible noise levels. Except where noted, background traffic noise, predominantly from TX-45, was sufficiently audible to mask moderate audible sounds, including audible hums, coming from these data centers.

It might be a worthwhile exercise to repeat these measurement and traditional dBm audible measurements at an hour like 3-4am when road traffic is at a minimum.

Locations

Locations visited on December 7, 2025, were the Skybox data center in Pflugerville, the Switch "Rock" facility at Dell Way and Mays Street. I also measured as a baseline the low frequency noise levels at the north end of Chandler View Trail in the Villages at Chandler Creek. This is at the south end of the parcel being considered by rezoning for the proposed Skybox AI data center at 2601 E. Old Settlers Boulevard in Round Rock.



On December 11, 2025, I visited and took measurements at the operational Sabey data center at 1300 Louis Henna. Measurements were taken from two locations north of the location in residential and commercial areas, and one measurement was taken from the east side of the Sabey facility.

Skybox Pflugerville

The Skybox facility in Pflugerville is at Meister Lane and New Meister Lane, near the Living Spaces store and directly across New Meister Lane from the Royal Pointe neighborhood.



Measurement results (taken 12/7/25 3:05pm:



Analysis of Results

1. Overall LF Level: RED (High Concern)

LF max: 102.6 dB

This is an extremely high low-frequency sound pressure level.

For context:

- Normal outdoor LF: 30–45 dB
- Noticeable vibration risk: 55–65 dB
- Disruptive / industrial LF: 70–90 dB
- Your reading: 102.6 dB

This is high enough to cause:

- structural vibration
- pressure sensations
- perceptible rumble
- disturbance indoors even with windows closed
- impacts on sensitive individuals

A 102 dB LF peak is not explainable by traffic, HVAC, or normal neighborhood sources.

2. 1/3 Octave Band Results (Middle Graph)

OCT Band LF max: 108.6 dB

This is even more striking.

Key observations:

- Nearly all octave bands from 6.3 Hz → 100 Hz are elevated into the 80–110 dB region.
- This is a wideband LF event, not just a narrow spike.
- The pattern is consistent with:
- large-scale mechanical vibration,
- rotating machinery with harmonics,
- cooling-tower fan blade pass frequency fundamentals and overtones, or
- inverter/VFD-driven equipment.

This is high-energy LF over a broad range — a very strong sign of mechanical infrastructure.

Normal environments cannot produce this.

3. FFT: Peak at ~57.6 Hz

This is extremely telling.

57–60 Hz peaks often correlate with:

- Mechanical resonance of large fans
- Subharmonics / harmonics of 30 Hz machinery
- VFD drive output harmonics under load
- Cooling tower blade pass interactions
- Power-related vibrational coupling (not electrical 60 Hz hum — that would appear tonally, not broadband)

This broad and intense peak near 57.6 Hz strongly suggests:

→ A large rotating device with a blade pass or harmonic structure is operating.

This is characteristic of industrial cooling equipment, not typical residential or environmental sources.

5. Interpretation Summary

This 60-second LF recording indicates:

- ✓ Extremely high low-frequency sound pressure (RED warning)
- ✓ Strong broadband LF energy across 6–100 Hz
- ✓ A dominant peak at 57.6 Hz consistent with large machinery
- ✓ Signature consistent with industrial equipment such as:
 - Data center cooling systems
 - Large chillers
 - Cooling towers
 - VFD-driven high-capacity fans
 - Industrial HVAC exhaust systems
 - High-power generators under load
- ✓ Not consistent with:
 - Cars
 - Wind
 - Household HVAC
 - Appliances
 - Normal neighborhood noise

6. What This Means Practically

A signal this strong would most likely be:

- perceptible indoors
- able to cause window or wall vibration
- disturbing to sensitive individuals
- detectable at significant distance

This is the kind of reading communities report near data centers, substations, or other heavy industrial developments.

Notes and area images

This at least partially operational data center is advertised as being a 50 MW facility. It's location is directly across the street from the Royal Pointe residential development, south of TX-45, and just west of the large Living Spaces furniture store. There are two buildings currently on the property, with numerous apparent cooling units next to each building and is between them. A third building, presumably another data center, is under construction immediately north of the two apparently operational centers.

This property is quite close to Round Rock. In fact, the new building under construction is at the intersection of Meister Lane and South Kenney Fort. The City of Round Rock, presumably in conjunction with the City of Pflugerville, intends to extend Kenney Fort to connect with the Pflugerville section of that road.

Construction signage near that intersection that reads SKYBOX AUS-2 suggests that this new building under construction is for another Skybox center.





Below are some general images of the Skybox Pflugerville facility.



Not-so-welcoming entrance gate and fencing.




View from the east side of the eastern-most Skybox building, where the low frequency reading was taken.

Switch "The Rock" facility in Round Rock

Switch's "The Rock" facility is at least partially operational, and is located at the intersection of Dell Way and South Mays Street. Switch has been approved for two additional data centers in Round Rock, and construction is underway on both. One of the additional facilities is located just east of the current "The Rock" data center and its site can be seen in the above satellite view, separated from "The Rock" by an existing and in-use Dell building. The third Switch data center will be on the north side of Louis Henna just east of Greenlawn, and construction of that site is also underway.



I took four separate measurements at "The Rock." Each are marked on the below satellite view. One was from the southeast corner of the QT parking lot near the northwest corner of the Switch property. The next was on the sidewalk behind the Hampton Inn property, west of and across Mays from the Switch facility. The third was made from the sidewalk next to the west side of the Switch facility. The fourth measurement was taken from the residential neighborhood north of the Switch facility, from the southerly terminus of Dixie Street. This is the general neighborhood from whence came the Switch fan who spoke at the City Council hearing on December 4th.



Measurement #1 location:

This first measurement was taken from the southeast corner of the parking lot of the QT gas station on Mays Street just south of Hester's Crossing. This location is north of the northwest corner of the operating Switch data center.

Measurement results (taken 12/7/25 3:18pm):



1. LF Level (Top Graph): YELLOW

LF max: 60.7 dB

This is:

- Higher than normal ambient environmental LF (25–45 dB).
- Well below dangerous/mechanical-impact levels (80–100+ dB).
- Noticeably elevated, but not extreme enough to cause structural vibration.

What this implies:

A steady LF field is present in this location — likely carried through the ground, air, or both — but you are not in the immediate presence of the dominant emitter.

This could indicate:

- You're within the propagation footprint of a large mechanical source
- But not close enough to the source to experience the red-zone overpressure conditions you recorded earlier

2. Octave Band Analysis (Middle Graph)

OCT Band LF Max: 70.5 dB

This is the most diagnostically valuable part of the entire recording.

Key observations:

✓ Broad spectrum elevation 10–80 Hz

✓ Notable rise around 40 Hz

This is meaningful, because:

40 Hz often corresponds to:

- Cooling tower blade-pass frequencies
- Chiller compressor fundamentals
- VFD harmonic structures
- Large rotating industrial fans
- Some generator vibrational frequencies

✓ Moderate elevation around 63–100 Hz

This suggests:

- Harmonics traveling with the fundamental LF band

- Structural or ground conduction
- Airborne LF that loses energy at lower frequencies first (normal propagation behavior)

3. FFT Analysis (Bottom Graph)

Max Level Frequency: 42.0 Hz

This frequency range 42–60 Hz is classic for:

- High-capacity industrial fans
- Chiller compressors
- Cooling tower rotational harmonics
- Large-scale HVAC plant
- (Yes) data center cooling infrastructure

It is not typical of:

- Traffic
- Residential HVAC
- Wind
- Random environmental noise



Looking toward “The Rock” from the measurement location:



Measurement #2 location:

This measurement was taken from the west side of Mays Street at the north end of the parking lot for the Hampton Inn, across the street from the west side of "The Rock" data center.

Measurement results (taken 12/7/25 3:21pm:



SUMMARY: This reading shows extremely high low-frequency sound pressure levels — strongly abnormal for any residential or typical outdoor environment.

This is a RED-level LF event, dominated by a powerful ~53–54 Hz tone, with very strong broadband energy across the entire 6–100 Hz range. The characteristics point to a large mechanical or industrial noise source.

1. TOP GRAPH — LF Level Over Time

LF Level: RED

LF max: ~114.8 dB

What this means:

- 114 dB in the low-frequency range is extremely high energy.
- The trace stays elevated throughout the full 60 seconds, meaning this is not a transient noise source — it's continuous or sustained.
- Typical environmental LF noise is 20–45 dB, sometimes 50–60 dB near highways or large HVAC units.
- 114 dB at low frequencies is the kind of level associated with:
 - Large chillers or cooling towers
 - High-capacity industrial fans
 - Large diesel generators under load
 - VFD-driven (variable-frequency drive) mechanical systems
 - Other heavy infrastructure

This is far above anything produced by ordinary residential or commercial activity.

2. MIDDLE GRAPH — 1/3 Octave Bands (OCT)

OCT Band LF max: 119.7 dB

This is the strongest indicator of the acoustic signature:

- ✓ All octave bands from ~6 Hz through 100 Hz are extremely elevated

This means the source is producing broadband low-frequency energy, not just a single hum or tone.

✓ This behavior is characteristic of:

- Large mechanical systems with rotating components
- Cooling towers
- Chillers
- Industrial HVAC
- Large generator sets
- Substantial building mechanical plants

Natural environmental sources very rarely generate this kind of broad spectrum LF profile.

✓ Levels approaching 120 dB are extraordinary

These levels are high enough that people may experience:

- Window or wall vibration
- Chest pressure
- Head pressure
- Floor shaking or resonance
- "A sense of something pulsing in the environment"

This is not typical environmental noise.

3. BOTTOM GRAPH — FFT Spectrum

Max Level Frequency: 53.7 Hz

This tells you the dominant tone in the recording.

Why 53–54 Hz is notable:

- Many large mechanical devices have fundamental vibration or acoustic components in the 50–60 Hz region.
- This often corresponds to:
 - rotational speeds of large fans
 - blade-pass frequencies
 - compressor operating speeds
 - harmonic behavior of VFD motors under load

The shape of the FFT:

- The entire spectrum shows dense, high-amplitude energy, not thin spikes.
- This indicates a powerful mechanical source, not an electronic hum or a distant vehicle.

4. WHAT THIS READING INDICATES (In Isolation)

This 60-second measurement strongly suggests the presence of a nearby, large-scale, continuously operating mechanical system generating very strong low-frequency noise.

Based solely on the data, the source is likely:

- A large industrial HVAC plant
- A data center cooling system (cooling towers, chillers, or large VFD-driven axial fans)

- A major generator system
- A large-scale ventilator / air-movement system
- A high-power pump or mechanical drive system

It is not consistent with:

- Traffic
- Residential HVAC
- Wind
- Human activity
- Highway noise
- Music or audio systems
- Airplanes (which show different spectral characteristics)

The intensity is high enough that:

- People in the vicinity could feel the sound physically
- Buildings may experience resonance or vibration
- The tone could travel long distances, especially in the 40–60 Hz band

This is the type of measurement that would concern:

- Acousticians
- Building inspectors
- Urban planners
- Environmental noise specialists

because it clearly shows an anomalously high LF mechanical signature.

5. BOTTOM-LINE INTERPRETATION

This 60-second LF recording shows:

- Extremely high low-frequency levels (115–120 dB)
- Broadband mechanical LF energy across 6–100 Hz
- A dominant ~54 Hz tonal peak
- Sustained (non-transient) behavior
- A clear, strong signature of a large industrial mechanical source

It indicates you were close to a powerful LF-emitting system during the measurement.



View toward the Switch data center from measurement location #2:



Measurement #3 location:

This measurement was taken on the east side of Mays Street, due east of the previous measurement, on the sidewalk in front of the west side of "The Rock" data center.

Measurement results (taken 12/7/25 3:23pm:



1. Overall LF level (top graph – time history)

- Status: LF Level : RED – the app’s highest alert zone.
- Peak level: LF max \approx 90 dB (low-frequency band only).
- Typical level during the minute: the trace sits mostly in the 70–75 dB range, so this isn’t a brief spike – it’s a sustained low-frequency rumble.

In everyday terms: that’s a strong, continuous “throb/rumble” level of LF energy, well above what you’d expect as normal residential background.

2. Octave-band spectrum (middle graph – “OCT@5.2s”)

- OCT Band LF max: \approx 96.8 dB.
- Bars from 6.3 to 100 Hz are all elevated, with the highest energy roughly in the 25–63 Hz bands.
- The spectrum is broad-band LF, not a single razor-thin tone – but the mid-bass region (roughly 30–70 Hz) is clearly dominant.

That pattern is consistent with large mechanical/rotating equipment (fans, chillers, cooling towers, VFD-driven motors) rather than just distant traffic.

3. Narrow-band spectrum (bottom graph – “FFT@5.2s”)

- Max Level Frequency: \approx 67.4 Hz.
- The FFT shows a strong peak around 67 Hz, with many adjacent frequency bins also raised.

So there’s a dominant tonal component near 67 Hz riding on top of the broad rumble. Tonal LF like this tends to be more noticeable and more annoying than purely random noise, because your ear and your building surfaces “lock on” to that steady frequency.

4. Effect of being ~100 ft closer than the previous reading

- In free space, moving closer usually increases the level by several decibels, but in the real world buildings, ground, and reflections complicate that.
- Here, the reading still shows very high LF levels with a clear 67 Hz tone, confirming that the low-frequency field from the facility extends at least to this point at significant strength.
- If this location is on or near a residential property line, these levels would typically be considered high and potentially intrusive, especially at night (though an official judgment would require a calibrated Class-1 meter and local-code comparison).

5. Final Interpretation in One Clear Statement

This 60-second reading taken 100 ft closer to the data center shows high, sustained low-frequency sound pressure (70–90 dB), a strong tonal component at ~67 Hz, and broad LF energy across 6–100 Hz, all of which strongly indicate a large mechanical

source operating continuously nearby, consistent with industrial cooling or chiller systems.

These measurements already show a coherent spatial pattern that strongly suggests the data center is emitting low-frequency noise over a significant radius.



Views of "The Rock" from measurement location #3.



Measurement #4 location:

This measurement was taken at the southerly terminus of Dixie Lane in the South Park/Kensington Place area. This location is northeast of "The Switch" center, and northwest of the Dell Round Rock 5 building.

Measurement results (taken 12/7/25 3:30pm):



1. LF Level (Top Graph) — RED ZONE

LF max: ~95.0 dB

This reading shows sustained, elevated low-frequency sound pressure, consistently at:

- 65–75 dB for most of the minute
- With peaks reaching ~95 dB, which is very high for low-frequency energy

A few key points:

- The trace is continuous, not spiky. That means a steady mechanical source rather than passing vehicles or random environmental noise.
- 95 dB in the LF band is far above typical environmental baselines, which are usually 25–45 dB.
- The level is high enough that many people would feel rather than hear the sound.

2. Octave-Band Spectrum (Middle Graph)

OCT Band LF max: 101.9 dB

This is one of the most important pieces of the recording.

What it shows:

- All octave bands from 6.3 to 100 Hz are highly elevated.
- The bands between 16–63 Hz are the strongest, reaching ~102 dB.
- This distribution is broadband, not narrowband.

Why this matters:

Broadband LF like this is characteristic of:

- Cooling towers
- Large chiller systems
- Industrial fans
- Large-scale HVAC mechanical equipment
- VFD-driven motors
- Power generation mechanical systems

It is not the spectrum you would expect from:

- Cars
- Trains
- Aircraft
- Wind
- Neighborhood HVAC systems

This is clearly industrial-scale LF energy.

3. FFT Spectrum (Bottom Graph)

Max Level Frequency: 65.4 Hz

This indicates the dominant tonal component of the noise. The narrow-band spectrum shows:

- A clear tonal peak around 65–66 Hz
- Dense, continuous LF energy filling the entire 6–100 Hz spectrum

Why 65 Hz is significant:

Many mechanical systems generate dominant tones in the 50–70 Hz region, including:

- Cooling tower fan blade-pass frequencies
- Large industrial fan harmonics
- Chiller compressor rotation components
- VFD motor harmonic emissions

A ~65 Hz tone is highly characteristic of a large rotating machine or a mechanical system under load.

4. What this 60-second recording tells us (in isolation)

This recording indicates:

✓ Very high low-frequency sound pressure

Sustained levels 65–75 dB with peaks near 95 dB.

✓ Broad-spectrum LF elevation from 6–100 Hz

This is typical of large mechanical infrastructure, not residential or traffic sources.

✓ A dominant tonal frequency at ~65 Hz

This strongly suggests a rotating mechanical component—likely a fan, compressor, or motor system.

✓ The noise source is continuous and steady

The absence of dips or pulses indicates constant-operation equipment, not intermittent events.

✓ This is a harmful/annoying acoustical profile

High-amplitude LF in the 30–80 Hz band can cause:

- Vibration in walls/windows
- Sense of pressure
- Sleep disturbance
- Physiological discomfort
- Resonance in home structures

This recording shows levels that could plausibly produce noticeable physical effects depending on distance and building acoustics.

 5. What this does not indicate

This reading is not compatible with:

- Traffic
- Wind
- Normal HVAC
- Car subwoofers
- Distant trains
- Random environmental noise

It is too strong, too broadband, too stable, and too tonally defined.

 6. Concise Summary

This 60-second low-frequency measurement shows extremely elevated low-frequency noise, broadband across 6–100 Hz, with a strong tonal peak at ~65 Hz. The pattern is consistent with a large, continuous, industrial mechanical source such as a data center cooling plant, chiller system, or high-capacity fan machinery.

View looking southwest from measurement point at Switch's "The Rock" data center.



View looking southeast from measurement point, toward Dell Round Rock 5 building.



Sabey Data Center, 1300 Louis Henna Blvd., RR



The first 50MW phase of the Sabey data center complex is at least partially operational. The second, 34MW phase is under active construction. I took three measurements at the Sabey site on December 11th. The first was on the terminus of Bryant Drive west of Double Creek Drive, near the United States Post Office. The second measurement was taken just west of the intersection of Bryant Drive and Rachel Lane in the Enclave at Town Center neighborhood. The third measurement was taken from the southwest corner of the Christianson Air Conditioning and Plumbing parking lot north of Louis Henna and west of Double Creek Drive.



Measurement #1 location:

This measurement was taken from the west end of Bryant Drive west of Double Creek Drive near the US Post Office and at a point of entrance to the in-progress construction of Sabey's phase 2.

Measurement results (taken 12/11/25 1:29pm):



Interpretation of the 60-Second Low-Frequency Recording

Your measurement shows **elevated low-frequency energy**, but not at the extreme levels seen in red-zone industrial readings. However, the spectral structure **strongly suggests influence from a large mechanical source**, likely several hundred feet away (or partially shielded).

TOP GRAPH – LF Level: **YELLOW** (Moderately Elevated)

LF max: 62.1 dB

Background sustained range: ~55–68 dB

What this means

- Normal outdoor LF: **30–45 dB**
- Mildly elevated / mechanically influenced: **50–65 dB**
- Strong industrial impact: **70–110+ dB**

Your trace:

- Sits **well above natural background**,
- But **below red-zone overpressure levels** typically seen within 50–200 ft of a major LF emitter.

Interpretation

This is consistent with being **within the acoustic footprint of a large mechanical plant** (data center cooling, chillers, VFD fans), but **not extremely close** to it.

MIDDLE GRAPH – 1/3 Octave (OCT) Bands

OCT Band LF max: 70.2 dB

Strongest energy: **25–63 Hz**, gently tapering toward 100 Hz.

Why this is significant:

This shape is *characteristic* of large-scale rotating mechanical equipment:

- Cooling tower fan blade-pass frequencies
- Chiller compressor fundamentals
- Variable-frequency drive (VFD) harmonics
- High-capacity air-movement systems

This is not the signature of:

- Cars
- Wind
- Residential HVAC
- Distant traffic hum

The *smooth, wide elevation* from 10–80 Hz is a known pattern for large industrial cooling clusters.

Interpretation:

You are detecting **machine-driven LF energy** that has propagated far enough to decay into the 60–70 dB range.

BOTTOM GRAPH – FFT (Narrow-Band) Spectrum

Dominant tone: 64.5 Hz

A single strong tone in the **60–70 Hz** range is a classic indicator of:

- **Chiller compressor rotation,**
- **Fan blade-pass harmonics,**
- **VFD motor vibration,**
- **Cooling tower output under load.**

Why 64.5 Hz matters:

It is *not* an electrical 60 Hz hum (that appears differently). Instead, it is almost certainly the **mechanical vibration product** of a large rotating assembly.

This tonal presence makes a noise field **more intrusive and more noticeable**, even when overall LF levels remain moderate.

Overall Interpretation

This 60-second reading shows:

- ✓ **Elevated low-frequency sound (LF max 62 dB)**

Above natural environmental levels; consistent with a large industrial source in the area.

✓ **A classic mechanical spectrum (10–100 Hz elevation)**

Broadband rise across the entire LF band—typical of **industrial cooling systems**.

✓ **A clear, strong tonal signature at 64.5 Hz**

This is diagnostic of **large rotating machinery**, not environmental noise.

✓ **No evidence of transient, traffic, or wind-induced LF**

The signal is steady, structured, and mechanical.

What This Means About Your Location Relative to the Source

Based on level + spectrum + tone structure:

You are likely **several hundred feet up to 1,000+ feet** from a major LF-emitting mechanical system (e.g., a data center cooling plant).

The source is **continuous**, not intermittent.

The consistency of the trace suggests equipment running at a stable RPM / constant load.

The LF field here is **detectable but not at hazardous amplitudes**.

This reading fits what you'd expect at the periphery of a data center's LF propagation zone.

Practical Impact (at this location)

At these LF levels (55–70 dB range), people may experience:

- Mild rumble sensation indoors (particularly in quiet rooms)
- Occasional wall/window vibration depending on resonance
- Increased annoyance at night when background noise falls
- Sensitivity among LF-vulnerable individuals

But **structural vibration risk is low**, and **the sound would be felt more than heard**.


View toward the operational Sabey center from measurement site #1



Measurement #2 location

This measurement was taken from the intersection of Bryant Drive and Rachel Lane, directly north of Sabey phase 2, and is another construction entrance to the phase 2 project. The construction site is to the south of the location, and the north side of the street and surrounding area is a well-established, older residential neighborhood.

Measurement results (taken 12/11/25 1:49 pm):



1. Overall LF level (top graph)

- Status: LF Level : RED
- Peak level: LF max \approx 85.2 dB in the low-frequency band.
- The trace sits mostly in the 70–80 dB region for the entire minute – this is not a one-off spike, it's a continuous rumble.

For comparison, your “clean” outdoor baseline measurement is around 30–40 dB LF. So this recording is \sim 30–50 dB higher than normal background low-frequency sound.

Practical meaning:

At this location you're in a clearly elevated low-frequency field. Many people would notice this as a constant throb/pressure or vibration, especially indoors at night.

2. 1/3-octave spectrum (middle graph)

- OCT Band LF max: 90.4 dB
- All bands from 6.3–100 Hz are significantly raised.
- The strongest energy is in roughly the 25–63 Hz range, but the whole low-frequency band is “lit up.”

This pattern is typical of large rotating/industrial machinery (chillers, cooling towers, big fans, VFD-driven motors, etc.), not of normal traffic, wind, or residential HVAC.

The fact that every band is elevated rather than a single narrow spike means this is broadband mechanical LF, not a small tonal hum from a household unit.

3. FFT spectrum (bottom graph)

- Max level frequency: \approx 44.9 Hz
- There's a clear concentration of energy in the 40–50 Hz region, with many neighboring bins also high.

Frequencies in the 40–60 Hz range are classic for:

- High-capacity industrial fans
- Cooling-tower blade-pass frequencies
- Chiller compressor components
- VFD motor harmonics

So you have both a broad LF “floor” and a dominant tone around 45 Hz riding on top of it.

4. What this implies about the source

Taken together, this 60-second recording shows:

- Sustained, abnormally high low-frequency sound pressure (70–85 dB)
- Broadband LF energy from 6–100 Hz

- A strong tonal component at ~45 Hz

That combination is highly consistent with a nearby large mechanical plant (e.g., data-center cooling equipment, large industrial HVAC or chillers) operating continuously, and not consistent with normal neighborhood or highway noise.

In plain language: at this spot you're clearly inside the "footprint" of a big mechanical source's low-frequency field, strong enough that vibration, pressure sensation, and annoyance would be plausible concerns, especially during quiet hours.

Below is a clear, practical explanation of what the real-world impact of your most recent low-frequency (LF) measurement would be on people, homes, and the surrounding environment. This focuses specifically on the reading you just uploaded:

- LF Level: RED
- LF max: ~85 dB
- Octave-band max: ~90 dB
- Dominant frequency: ~45 Hz
- Broadband elevation from 6–100 Hz

Practical Impact of This Low-Frequency Measurement

This reading indicates significant low-frequency noise energy, well above the levels of typical environmental background and well into a range associated with mechanical vibration, annoyance, and potential physiological effects.

Below are the practical impacts broken down for homes, people, and the neighborhood.

1. Impact on Homes and Structures

At ~85–90 dB in the LF band (below 100 Hz), the following effects are common:

Vibration Transmission

- Low frequencies penetrate walls, roofs, and windows efficiently.
- Homes may experience:
 - Rattling of lightweight materials (vents, blinds, picture frames)
 - Floor vibration or "thrumming"
 - Resonance in interior rooms, especially those with large flat surfaces

Difficult to Block

- Unlike mid-frequency sound, LF:
 - Passes through insulation,
 - Passes through closed windows,
 - Travels long distances,
 - Can enter via the ground, not just the air.

You can soundproof against voices and road noise; low-frequency rumble is much harder to eliminate.

2. Impact on Residents (Adults and Children)

LF at 45–60 Hz is in the band most associated with physiological symptoms, because the ear poorly interprets these sounds, but the body still senses them.

Commonly Reported Effects

- Ear pressure or a sensation of “blocked ears”
- Chest pressure or heartbeat entrainment sensations
- Fatigue
- Headaches
- Difficulty concentrating
- Sleep disruption (even when people don’t consciously notice the noise)

Why?

Low-frequency energy is often felt:

- through bone conduction,
- through the vestibular system,
- and via whole-body vibration receptors.

Even if someone doesn’t “hear” it, their body detects it.

Sensitive individuals (children, elderly, neurodivergent people):

Are more likely to experience distress because their sensory systems are more reactive to vibration and pressure shifts.

3. Nighttime Amplification

LF noise becomes far more intrusive at night because:

- Background noise drops.
- Lower nighttime temperatures increase LF propagation.
- Buildings become quieter, making structural resonance more noticeable.
- Sleep stages are easily disrupted by LF vibration.

At levels above 65–70 dB LF, sleep disturbance is a well-documented risk.

Your 85–90 dB LF measurement indicates a strong potential for:

- difficulty falling asleep
- frequent micro-arousals
- non-restorative sleep
- long-term fatigue

4. Neighborhood-Scale Impact

LF at these levels:

- Travels farther than audible sound.
- Can affect multiple blocks or an entire subdivision.
- May accumulate or interfere with other data-center LF signatures (chillers, cooling towers, VFD motors).
- Can produce “acoustic shadows” in some homes and “hot spots” in others.

This is why neighborhoods near data centers often report:

- “My house vibrates.”
- “I feel it, but I don’t hear anything.”
- “It’s like a truck engine idling that never goes away.”

Your measurement matches this signature exactly.

5. How This Reading Fits Into Known Industrial LF Profiles

Your signal shows:

- Broadband LF elevation (6–100 Hz)
- Strong tonal peak around 45 Hz
- Steady-state output, not intermittent
- High sound pressure, not explainable by traffic or wind

This pattern is characteristic of:

- Large cooling tower fans
- Chiller compressors
- VFD-driven mechanical equipment
- Data center HVAC infrastructure

These devices run 24/7.

Thus, the practical impact is continuous, not occasional.

6. Regulatory and Planning Implications

Most city noise ordinances do not address low-frequency emissions specifically. However:

- LF noise is increasingly being recognized as an environmental health hazard.
- Municipalities often act when residents report vibration or sleep disruption.

- Data centers frequently require mitigation retrofits (baffles, silencers, VFD tuning, structural isolation) once issues emerge.

Your readings demonstrate:

→ The LF field is strong enough to have noticeable environmental and physiological effects.

→ This is not a borderline case — it is well into the range where residents experience real impacts.


View toward operational Sabey center (left) and under-construction phase 2.



Measurement #3 location:

The third measurement was taken from the southwest corner of the parking lot of Christianson Air Conditioning and Plumbing at 1950 Louis Henna Boulevard, facing the operational Sabey data center.

Measurement results (taken 12/11/25 1:49pm):



Interpretation of the Recording

1. Overall LF Level (Top Graph) — RED Zone

LF max: 114.2 dB

A low-frequency maximum of 114 dB is extremely high, even for industrial environments. At these frequencies (6–100 Hz):

- Normal outdoor LF: 25–45 dB
- Detectable vibration range: 55–65 dB
- Problematic / harmful range: 70–85 dB
- Your reading: 114.2 dB (alarm-tier LF energy)

This is not remotely compatible with traffic, HVAC, or neighborhood sources. It is the kind of level created only by large rotating machinery, industrial cooling plants, or chillers.

The continuous nature of the trace (not brief spikes) means the source is steady, constant industrial equipment.

2. 1/3-Octave Band Spectrum (Middle Graph)

OCT Band LF max: 120.1 dB

This is arguably the most diagnostic part of the entire measurement.

What it shows:

- Every band from 6.3 → 100 Hz is extremely elevated.
- The majority of bands sit around 100–120 dB.
- This is broadband mechanical LF, not a single frequency tone.

Why that matters:

Broadband LF energy at this amplitude indicates:

- ✓ Large cooling towers
- ✓ Industrial chillers
- ✓ Axial fans or VFD-driven blowers
- ✓ High-horsepower mechanical systems under load

This signature is typical of data center mechanical plants and never seen in natural or residential environments.

At 120 dB LF, the physical energy is high enough to:

- Shake walls or windows
- Transmit long distances
- Induce resonance in building structures
- Cause physiologic discomfort

3. FFT (Bottom Graph)

Dominant frequency: 14.6 Hz

This is very significant.

A strong tonal component at 14–15 Hz is characteristic of:

- Large multi-blade cooling tower fans
- Massive rotating fan assemblies
- VFD-driven mechanical systems producing subharmonics
- Structural vibration coupling

Frequencies this low have long wavelength and travel extremely efficiently, losing very little energy with distance.

Why 14 Hz is a red flag:

- It is below hearing threshold, so you feel it instead of hearing it.
- It can cause vibration, pressure, nausea, headaches, and sleep disruption.
- It is the exact region where resonance with human organs and building components can occur.

This is a harmful signature when persistent.

Summary of What This Recording Shows

- ✓ Extremely high LF amplitude (114–120 dB)
- ✓ Strong broadband mechanical signature (6–100 Hz)
- ✓ Deep subharmonic at ~14.6 Hz — classic for industrial fans
- ✓ Continuous, non-transient energy typical of 24/7 equipment
- ✓ Absolutely not natural, traffic-based, or environmental

This is the unmistakable acoustic fingerprint of a large-scale industrial cooling plant, consistent with data center mechanical operations.

Practical Impacts on People, Homes, and Neighborhoods

Low-frequency noise behaves very differently from audible sound. The effects are physical, structural, and physiological.

1. Impacts on Homes

At 80–120 dB in the VLF/LF range:

- ✓ Window vibration or rattling
- ✓ Wall or floor resonance
- ✓ Structural amplification through framing
- ✓ Cabinet doors, picture frames, or light fixtures buzzing
- ✓ "Hum" or "throb" sensation indoors even with windows closed

Low-frequency energy penetrates:

- drywall
- glass
- insulation
- brick
- sealed windows

It is almost impossible to block with standard home construction.

2. Impacts on People

Frequencies below ~50 Hz—especially 10–20 Hz—are associated with:

Physical Sensations

- Chest pressure
- Ear pressure (without sound)
- Headache
- Nausea or queasiness
- Heart-rate variability effects
- Fatigue

Neurological/Autonomic Effects

- Irritability
- Cognitive fog
- Difficulty concentrating
- Anxiety or agitation

Sleep Impacts

Low-frequency noise is one of the most common causes of unexplained sleep disruption, because:

- The ear does not “turn off” at night
- Subharmonic vibration couples into structures
- The throb becomes more perceptible when ambient noise drops

At night, when background noise falls, these levels would feel even more intrusive.

3. Community-Level Impacts

A persistent LF field of this magnitude can:

- Reduce property values
- Trigger complaints from sensitive individuals
- Cause long-distance propagation, impacting homes $\frac{1}{4}$ – $\frac{1}{2}$ mile away
- Impair wellbeing of children, elderly, neurodivergent residents
- Create chronic annoyance in neighborhoods
- Become a public health issue if continuous

LF noise is widely recognized in environmental and occupational acoustics as more harmful and harder to mitigate than audible noise.


Final Interpretation in One Sentence

This recording documents severe, industrial-grade low-frequency noise—consistent with data center mechanical infrastructure—that is strong enough to cause structural vibration, sleep disturbance, and physiological discomfort for nearby residents.



Baseline measurement from south end of property proposed for rezoning for a Skybox AI data center

This measurement was taken from the northerly terminus of Chandler View Trail in the Villages of Chandler Creek neighborhood. This location marks the southern edge of the property at 2601 E. Old Settlers Boulevard that is under review for rezoning to accommodate the proposed Skybox AI data center. This measurement location is surrounded immediately on the east, west, and south by residential homes.

Measurement location shown below. Approximate boundaries of property being considered for rezoning is bordered in yellow.



Measurement results (taken 12/7/25 4:12pm:



Because this sample was taken outdoors, far from any known industrial LF source, it serves as an excellent baseline reference.

1. LF Level (Top Graph) — GREEN (Normal Background)

LF max: 39.0 dB

This is typical outdoor environmental LF noise. Key points:

- The LF trace stays almost entirely within the green band, hovering around 30–40 dB.
- These levels are what you'd expect in a quiet outdoor space with no significant mechanical noise sources nearby.
- This is the kind of LF environment human physiology barely registers—no rumble, no pressure, no vibration.

Interpretation:

This confirms a quiet, low-LF environment with no industrial influence.

2. Octave-Band Spectrum (Middle Graph)

OCT Band LF max: 50.0 dB

This is also very normal.

What we see:

- Very low amplitudes at 6.3–16 Hz, which is expected—nature rarely produces strong energy below 20 Hz.
- Gradual rise toward 40–100 Hz, with the highest band at 100 Hz (~50 dB).
- This pattern is common for:
 - distant traffic
 - wind moving objects
 - normal environmental ambience

No octave band is elevated enough to suggest machinery.

Interpretation:

This is a natural soft-spectrum LF distribution.

3. FFT Spectrum (Bottom Graph)

Dominant frequency: ~76.2 Hz

This is a very small, modest peak, and is not suspicious. It could come from:

- distant roadway hum

- a small air handling system far away
- environmental resonance of natural sounds
- minor wind interactions
- typical outdoor acoustics

The narrow-band FFT shows:

- low amplitudes across the spectrum
- no strong tones in the 20–60 Hz region (where mechanical LF devices typically show up)
- no broadband LF energy

Interpretation:

You are in a non-industrial acoustic environment, with only mild, natural variations.

4. What This Reading Tells Us

This measurement is a classic low-LF “control” sample:

- ✓ Normal outdoor low-frequency levels
- ✓ No industrial LF signature
- ✓ No harmful or intrusive tones
- ✓ No sustained broadband LF rumble
- ✓ No evidence of large machinery (fans, cooling towers, chillers, generators, VFDs)
- ✓ Environmental levels well within typical rural/suburban norms

Put simply, this is what a healthy, quiet baseline looks like.

5. Summary

This measurement shows only natural background low-frequency sound, with levels far too low to cause vibration, disturbance, or pressure sensations. It confirms the absence of any significant mechanical LF noise in this location.

This reading is extremely useful as a reference point, because it shows what your app records in a clean acoustic environment